

Phone : 022-25594695
Fax : 022-25505311



Room No - 94,
Dhruva, RRMD,
BARC, Trombay,
Mumbai - 400085

सत्यमेव जयते

GOVERNMENT OF INDIA
BHABHA ATOMIC RESEARCH CENTRE
RESEARCH REACTOR MAINTENANCE DIVISION
ELECTRICAL MAINTENANCE SECTION, DHRUVA

Tender Notice No: RRMD / TN/04 / 2019

Date: 17-01-2019

31/1/2019

Sub: Tender enquiry for Supply and installation of Automatic Fire curtain in the existing partition wall cut-out at P-4, BARC.

Sealed tenders are invited for and on behalf of the President of India by the Head, RRMD, BARC, Trombay, Mumbai-400085 from experienced vendors for the supply and installation of Automatic Fire curtain in the existing partition wall cut-out at P-4, BARC as per the following terms and conditions.

1.0 Description of the work:

1.1 Supply of Automatic Fire curtain for passage/cut-out size of 2500mm(W)X2500mm(H) and other materials that may be required for complete execution of the job.

1.2 Installation, testing and commissioning of the above mentioned Automatic Fire curtain.

2.0 Terms and conditions:

2.1 The offer should be valid for consideration for 60 days from due date of the offer.

2.2 Contractor should complete the whole job in 5 months after receipt of work order.

2.3 On complete execution of the work to our satisfaction, payment would be released on submission of bills in triplicate along with an advance stamped receipt as a single payment.

2.4 The vendor should also clearly reply in his tender to "whether the contractor / vendor has any relative working in BARC or the contractor himself is an ex-employee of BARC or the contractor has any ex-employee of DAE on his payroll".

2.5 Since the job has to be carried out at our site P-4, BARC, the employees deputed at site by the contractor should have a valid police verification certificate.

2.6 Contractor should mention their valid PAN No. and GST / Service Tax Reg. No. in the quotation, failing which the offer shall be rejected.

3.0 Instructions to tenderers:

3.1 GST exemption certificate may not be provided as this work is not directly related to R&D.

3.2 Tenderers should submit documents in support of their technical capabilities.

3.3 Price quoted shall be filled up in the same format given in the Schedule-B with GST and Service tax if any and no other charges will be payable.

3.4 Tender shall be submitted in the sealed cover in the vendor's standard company format quoting our Tender no. on the envelope and addressed to 'Head, RRMD, BARC, Trombay, Mumbai-400085 and

submitted in the RRMD office, Dhruva'. The offers should be submitted so as to reach RRMD office, Dhruva on or before 14 February 2019 at 1500 Hrs.

- 3.5 Tenders shall be opened on the same or next working day in RG office, Dhruva Trombay, BARC and interested parties may be present at the time of opening of the tender with prior intimation. Shri R. Paramaguru / Shri. Mayank Kothiyal may be contacted at least two days in advance to arrange entry permit in this regard on phone no. 25591297 / 25596272 from 10 AM to 5 PM.
- 3.6 The acceptance of the tenders will rest with Head, RRMD who does not bind himself to accept the lowest offer, and reserves to him the authority to reject any or all the tenders received without assigning any reason.
- 3.7 Quotation/s received after the due date and time shall be summarily rejected.

AB
25/1/19

Thanking you,

Yours faithfully,

(P.Sumanth)
Head, RRMD

(For and on behalf of the President of India)

पी. सुमन्त / P. SUMANTH
अध्यक्ष, अरिआन / Head, RRMD
भापअकें / BARC

Encls: 1. Schedule -A&B
2. Annexure

Schedule –A

Tender Notice No: RRMD/TN/04 /2019 dtd. 31-01-2019.

Name of Work: Supply and installation of Automatic Fire curtain in the existing partition wall
cut-out at P-4, BARC.

Sl. No.	Description	Qty	Unit	Rate
1.	Water	As required	Litre	Free
2.	Electricity	As required	KWH	Free

Schedule – B

Tender Notice No: RRMD/TN/04/2019 dtd.31-01-2019.

Name of Work: Supply and installation of Automatic Fire curtain in the existing partition wall cut-out at P-4, BARC.

Sl. No.	Description of items	Unit	Qty (a)					Amount
				Rate/ unit (b)	Total (c=axb)	GST (%)	GST (₹) (d)	Total (₹) (e=c+d)
1	Supply of Automatic Fire curtain for passage/ cut-out size of 2500mm(W)X2500mm(H) and other materials that may be required for complete execution of the job.	No.	1					
2	Installation, testing and commissioning of the above mentioned Automatic Fire curtain.	No.	1					
Grand Total (₹)								
(Grand total in Rupees _____ only)								

Signature of the contractor with seal

Note: The prices shall be quoted in numerals and words as well. All pages of this form shall be signed with seal.

Annexure

SPECIFICATIONS

1. Dimensions

Sl. No.	Item Description	No. of Unit	Width (mm)	Drop (mm)
1.	Supply and installation of Automatic Fire Curtain with control panel.	1	2700	2700

2. Fire Curtain Specification

Conformance of system	EN 1634-1:2008
Fire Integrity	Min 4 hours @1000deg.C
Curtain Fabric	Class 0 Fire Rated
Power supply	240V/50 Hz (15 A max)
Headboxing material	Galvanized/ powder coated steel
Side Guides/channels	Galvanized/ powder coated steel
Bottom bar assembly	Galvanized/ powder coated steel
Falling mechanism	100% true gravity fall (Fail safe)
Raising and Lowering	Through electrical motor/s with limit switches.
Contact input	One contact from fire alarm system
Manual operation	It should be possible to operate the curtain manually through switches on control panel.

3. Installation and Warranty

The curtain top box/headbox shall be mounted on the brick wall above the lintel through anchor bolts. The height of room is around 5.8 m. The side channels/guides shall also be mounted on the brick wall through anchor bolts. The product shall be warranted for minimum of 1 year duration from the date of commissioning.

4. Documents required with offer

The offer should include the make and model number of the product with datasheets and certificates for conformance. The offer without supporting documents shall not be considered.